

DECLARATION OF CONFORMITY Cleanroom Qualification

With reference to the client **INTERAPP - VALCOM SPAIN** and the project "*Cleanroom for valve cleaning*", the following is hereby stated:

The cleanroom has undergone an IQ/OQ/PQ qualification process of the HVAC system and associated architectural elements, in accordance with the approved qualification protocol (**Qualification Report Code: INIQOQPQQ2385 v.01**), complying with Good Manufacturing Practices (GMP) and ISO 14644-1.

During the qualification process, the following aspects were verified, among others:

- Installation and configuration of the HVAC system
- System operation under defined conditions
- HEPA filter integrity
- Airflow rates and air changes per hour
- Differential pressures between rooms
- Airflow visualization tests
- Particle counting

The results obtained meet the acceptance criteria defined in the protocol, concluding that the cleanroom is compliant and suitable for its intended use.

Based on the particle count results and in accordance with **ISO 14644-1**, the cleanroom has been qualified with the following classification:

- **ISO Class 7**

This classification corresponds to the ISO class defined and verified in the Final Qualification Report.

Date: 28 / JAN / 2026

Project: **Cleanroom for valve cleaning**

This declaration is issued as a summary statement and is fully supported by the Final IQ/OQ/PQ Qualification Report (Code: INIQOQPQQ2385 v.01).

Yours sincerely,

Technical Department
MONTAJES DELSAZ, S.L.U.

MONTAJES DELSAZ, S.L.U.
B80538887
Calle Siete Picos, 5
28108 Alcobendas - Madrid